



# Addendum No. 3 to Contract Documents

Project	Grit Removal and Plant Modifications Ithaca Area Wastewater Treatment Facility	Project No.	11153020
Owner	City of Ithaca, NY Town of Ithaca, NY Town of Dryden, NY	Federal Project No.	--
Contract No.	1 - General 2 - Electrical 3 - HVAC	Date	November 12, 2019


To All Contractors:

Contractors submitting proposals for the above-named project shall take note of the following changes, additions, deletions, clarifications, etc., in the Contract Documents, which shall become a part of and have precedence over anything contrarily shown or described in the Contract Documents, and all such shall be taken into consideration and be included in the Contractor's Bid Proposal.

*Please see attached pages.*

The return receipt requested with this communication is to be deemed evidence that the bidder has received this addendum and has followed the instructions outlined therein.



  
Bruce G. Munn, P.E.



### Addendum No. 3 to Contract Documents

Grit Removal and Plant Modifications  
Ithaca Area Wastewater Treatment Facility  
City of Ithaca, NY; Town of Ithaca, NY; Town of Dryden, NY  
Contract No. 1 - General  
Contract No. 2 - Electrical  
Contract No. 3 - HVAC  
GHD Project No. 11153020  
November 12, 2019

Item No. 1:

Section 01010, Summary of Work. **DELETE** paragraph 1.13.B.7 and **REPLACE** with the following:

- “7. Temporary biogas piping and all required appurtenances shall be provided as needed to maintain the flow of biogas piping through the treatment plant during construction to accommodate the installation of the new biogas piping and gas safety equipment.”

Item No. 2:

Section 02698, Underground Process Piping. **DELETE** the table included in Article 3.10 and **REPLACE** with the following table:

Pipe No.	Identity	Predominant Size(s) (Inches)	Pipe Material	Schedule or Class	Joints	Test Procedure
2	Raw Wastewater	30	DIP	Class 53	Restrained mechanical	A
7	Process Drain	4, 6, 8	DIP	Class 53	Restrained mechanical	D
14	Storm Drain	4	DIP	Class 53	Restrained mechanical	D
43	Sump Pump Discharge	1.5	PVC	Schedule 80	Solvent weld	C
44	Process Drain	4	DIP	Class 53	Restrained mechanical	D

Item No. 3:

Section 16620, Packaged Engine Generator Systems. **DELETE** paragraph 2.02.A.2.

Item No. 4:

Contract Drawings, Sheet H002.

- A. **DELETE** note: “All Items This Area Part of ADD-ALT #B-5 Unless Specified Otherwise.”
- B. **ADD** note: “All Items This Area Part of ADD-ALT #B-13 Unless Specified Otherwise.”